

Work environment – **Outdoor environment**

15.03.08

# Markets, shows and sporting events gas, electrical & fire safety checklist >

This inspection safety checklist provides a guide for use by stall holders and authorized personnel and is valid for 12 months. It is a guide to achieve compliance with the Northern Territory [Dangerous Goods Regulations](#) and the Northern Territory [Workplace Health and Safety Regulations](#). The checklist may form part of stall holders safety management records.

Location	_____		
Owners name	_____		
Stall number	_____		
<b>Gas inspection</b>			
Inspection date	_____	Re-inspection date	_____
Compliance plate no	_____		
Gas fitting certificate no	_____		
Gas fitters name	_____		
Gas fitters signature	_____		
<b>Fire equipment</b>			
Inspection date	_____	Re-inspection date	_____
Inspected by	_____		
<b>Portable electrical inspection by competent person/electrician</b>			
Inspection date	_____	Re-inspection date	_____
Inspectors name	_____	Licence number	_____
Competent person/ electrician signature	_____		

putting safety first >



## Gas safety check list

Gas safety	Yes	No	Action
Compliance plate fitted	<input type="checkbox"/>	<input type="checkbox"/>	
Size of cylinder in operation (.....) – Number of bottles (.....)	<input type="checkbox"/>	<input type="checkbox"/>	
Cylinders secure or crated	<input type="checkbox"/>	<input type="checkbox"/>	
Cylinders under 10 years old or tested for use	<input type="checkbox"/>	<input type="checkbox"/>	
Twin stage regulators fitted rigidly	<input type="checkbox"/>	<input type="checkbox"/>	
Regulator diaphragm mounted vertical	<input type="checkbox"/>	<input type="checkbox"/>	
Quick release fittings on appliances and hoses	<input type="checkbox"/>	<input type="checkbox"/>	
Gas hose lengths less than 1.5 m	<input type="checkbox"/>	<input type="checkbox"/>	
Gas hoses and fittings in good condition	<input type="checkbox"/>	<input type="checkbox"/>	
Gas appliances are approved for commercial use	<input type="checkbox"/>	<input type="checkbox"/>	
Type B appliance in use	<input type="checkbox"/>	<input type="checkbox"/>	
Benches used for gas appliances are of a sturdy construction	<input type="checkbox"/>	<input type="checkbox"/>	
Gas appliances are secured to bench tops	<input type="checkbox"/>	<input type="checkbox"/>	
Non-combustible bench tops used for gas appliances i.e. (Metal top)	<input type="checkbox"/>	<input type="checkbox"/>	
Medium pressure appliances used - Require NT WorkSafe Approval	<input type="checkbox"/>	<input type="checkbox"/>	
Low pressure appliances used in operation – (Maximum 3 kPa)	<input type="checkbox"/>	<input type="checkbox"/>	

### Comments

---



---



---



---

## Fire safety check list

Fire safety	Yes	No	Action
1.5 KG (E) Type Dry Chemical Fire Extinguisher	<input type="checkbox"/>	<input type="checkbox"/>	
Extinguisher tested and valid for use	<input type="checkbox"/>	<input type="checkbox"/>	
Extinguisher mounted and clearly visible	<input type="checkbox"/>	<input type="checkbox"/>	
1 x Fire blanket clearly visible where deep fryers used	<input type="checkbox"/>	<input type="checkbox"/>	

### Comments

---



---



---



---

**Electrical safety check list**

Electrical safety	Yes	No	Action
Electrical appliances inspected and passed for use	<input type="checkbox"/>	<input type="checkbox"/>	
Extension leads inspected and passed for use	<input type="checkbox"/>	<input type="checkbox"/>	
Extension leads from distribution box to stalls heavy-duty 15 amp.	<input type="checkbox"/>	<input type="checkbox"/>	
Over head leads are supported at minimum of 3m intervals	<input type="checkbox"/>	<input type="checkbox"/>	
Over head leads at minimum of 2.5m in height / over roads 5.5m	<input type="checkbox"/>	<input type="checkbox"/>	
Portable power boards individually switched	<input type="checkbox"/>	<input type="checkbox"/>	
No extension leads at floor level in access / egress / walkways	<input type="checkbox"/>	<input type="checkbox"/>	
Double pole switching in vans and caravans	<input type="checkbox"/>	<input type="checkbox"/>	

**Comments**

---



---



---



---

**Further comments**

---



---



---



---



---



---



---



---



---



---

**NT WorkSafe >**

**GPO Box 1722  
Darwin NT 0801**

**Telephone:** 1800 019 115  
**Facsimile:** (08) 8999 5141  
**Email:** [ntworksafe@nt.gov.au](mailto:ntworksafe@nt.gov.au)  
**Website:** [worksafe.nt.gov.au](http://worksafe.nt.gov.au)